

	Element		2022 Sample	2025 Sample	Units	Max. Limit in Drinking Water
1)	Aluminium	Al	0.227	<0.010	mg/L	No limit listed
2)	Antimony	Sb	<0.500	<0.500	µg/L	6.00 µg/L
3)	Arsenic	As	<0.500	<0.500	µg/L	10.0 µg/L
4)	Barium	Ba	0.054	0.034	mg/L	2.00 mg/L
5)	Beryllium	Be	<0.003	<0.003	mg/L	No limit listed
6)	Boron	B	1.14	.869	mg/L	5.00 mg/L
7)	Cadmium	Cd	<0.010	<0.010	µg/L	7.00 µg/L
8)	Calcium	Ca	40.0	32.1	mg/L	200 mg/L
9)	Chromium	Cr	<0.003	<0.003	mg/L	0.050 mg/L
10)	Cobalt	Co	<0.005	<0.005	mg/L	No limit listed
11)	Copper	Cu	0.290	0.460	mg/L	1.00 mg/L
12)	Gold	Au	<0.040	<0.040	mg/L	No limit listed
13)	Iron	Fe	0.053	0.013	mg/L	0.300 mg/L
14)	Lanthanum	La	<0.020	<0.020	mg/L	No limit listed
15)	Lead	Pb	1.49	1.98	µg/L	5.00 µg/L
16)	Magnesium	Mg	8.35	6.86	mg/L	50.0 mg/L
17)	Manganese	Mn	<0.004	<0.004	mg/L	0.120 MAC 0.20 AO
18)	Mercury	Hg	<0.010	<0.010	µg/L	1.00 µg/L
19)	Molybdenum	Mo	<0.005	<0.005	mg/L	No limit listed
20)	Nickel	Ni	<0.004	<0.004	mg/L	No limit listed
21)	Phosphorus	P	<0.010	0.030	mg/L	No limit listed
22)	Potassium	K	1.23	0.960	mg/L	No limit listed
23)	Scandium	Sc	<0.050	<0.050	mg/L	No limit listed
24)	Selenium	Se	<0.500	<0.500	µg/L	5.0 µg/L
26)	Silver	Ag	<0.010	<0.010	mg/L	No limit listed
27)	Sodium	Na	57.2	95.2	mg/L	200 mg/L
28)	Strontium	Sr	0.410	0.320	mg/L	No limit listed
29)	Tin	Sn	<0.020	<0.020	mg/L	No limit listed
30)	Titanium	Ti	<0.010	<0.010	mg/L	No limit listed
31)	Tungsten	W	<0.050	<0.050	mg/L	No limit listed
32)	Vanadium	V	<0.010	<0.010	mg/L	No limit listed
33)	Zinc	Zn	0.031	0.018	mg/L	5.00 mg/L
Hardness (mg/L CaCO ₃)			134	108	mg/L	Moderately hard
PH			7.69	8.14	units	7.0 to 10.5